



This document has been redacted for Critical Energy Infrastructure Information (CEII). 10/9/2015

East Bay Area Study

Jack P. Vaz, PE

August 2015

This report was prepared by the National Grid USA Service Company. It is made available to others upon expressed understanding that National Grid USA Service Company, any of their officers, directors, agents, or employees does not assume any warranty or representation with respect to the contents of this document or its accuracy or completeness.

Reviewed by: _____ Date: _____
Ryan Constable, Distribution Planning & Asset
Manager – New England, Network Strategy

Approved by: _____ Date: _____
Alan LaBarre, Director, Distribution Planning
and Asset Management, NE, Network Strategy

Table of Contents

Pages

1.	Executive Summary	4
2.	Introduction.....	7
2.1	Purpose.....	7
2.2	Problem	7
3.	Background.....	7
3.1	Scope	7
3.1.1	Geographic Scope	7
3.1.2	Electrical Scope.....	7
3.2	Area Load and Load Forecast	8
3.3	Active Projects	8
3.4	Limitations on Infrastructure Development	8
3.5	Assumptions & Guidelines.....	8
4.	Problem Identification	9
4.1	Thermal Loading	9
4.1.1	Normal Configuration - Thermal Loading	9
4.1.2	Contingency Configuration - Thermal Loading	10
4.2	Voltage Performance	11
4.3	Asset Condition.....	12
4.4	Additional Analysis	14
4.4.1	Reliability Performance.....	14
4.4.2	Arc Flash.....	15
4.4.3	Fault Duty/Short Circuit Availability	15
4.4.4	Reactive Compensation	15
5.	Plan Development	15
5.1	Consideration of Distributed Generation in Plan Development.....	15
5.2	Common Items	16
5.3	Plan – 1	17
5.4	Alternative Plans.....	20
5.4.1	Plan – 2	20
5.4.2	Plan – 3	22
5.4.3	Do Nothing.....	25
6.	Plan Considerations and Comparisons	26
6.1	Economic, Schedule, and Technical Comparisons	26
6.2	Non-Wires Alternatives Considerations	27
6.3	Permitting, Licensing, Real Estate, and Environmental Considerations	27
6.4	Planned Outage Considerations	28
6.5	Asset Physical Security Considerations.....	29
6.6	System Loss Analysis.....	29
7.	Conclusions and Recommendations.....	30
8.	Factors Influencing Futures Studies.....	31
9.	Appendix.....	32
9.1	Area Maps.....	33
9.2	One Line Diagrams.....	35
9.3	Loadflow Diagrams	44
9.4	CYME Radial Distribution Analysis Diagrams.....	49
9.5	Arc Flash Analysis	56
9.6	Fault Duty Analysis	57
9.7	Plan Development – Common Items.....	58
9.8	Plan Development – Plan 1.....	60
9.9	Plan Development – Plan 2.....	67

9.10	Plan Development – Plan 3	73
9.11	Distributed Generation Within the Study Area	78

LEGEND	
Al	Aluminum wire or cable
ARP	Asset Replacement Program
Cal/cm^2	Calories/square centimeter
capex	Capital expenditure (budget expenditure type)
Cu	Copper wire or cable
DPG	Distribution Planning Guide rev 1, dated February 2011
EMS	Energy Management System
GIS	Geographic Information System
ISO	Independent System Operator
kV	Kilovolts
LTC	Load Tap Changer
MVA	Megavolt Ampere
MVAR	Megavolt Ampere Reactive
MW	Megawatts
MWh	Megawatt hour
MOV	Metal-Oxide Varistor
NE	New England
opex	Operations/Maintenance expenditure (budget expenditure type)
PT	Potential Transformer
RAPR	Remote Access Pulse Recorder
RI	Rhode Island
PUC	Public Utility Commission
SN	Summer Normal Rating of Equipment
SE	Summer Emergency Rating of Equipment

1. Executive Summary

A comprehensive study of the East Bay area was performed to identify existing and potential future distribution system performance concerns. System evaluation included comparison of equipment loading to thermal (capacity) limits, contingency response capability (Distribution Planning Criteria), voltage performance (RI PUC requirements), breaker operating capability, arc flash review, reactive compensation performance, asset condition, and safety and environmental issues. The recommendations provide a comprehensive solution to address all the system performance concerns existing and anticipated in the study area thru 2030.

The most recent major infrastructure development investment in the study area occurred in the 1990's with the construction of Wampanoag substation in East Providence and the expansion of Bristol substation. These investments relieved a highly utilized distribution and sub-transmission system. New investments are required to provide additional relief to the supply and distribution systems in the area. Additionally, there are a number of asset condition, safety, and reliability concerns that need to be addressed.

Three plans were developed to address existing area problems and to provide for future needs within the study area thru the year 2030. Each plan provides a comprehensive solution to address all concerns in the study area. The concerns include thermal loading near or above rated capability of equipment, contingency response capability that does not meet distribution planning guidelines, asset condition concerns, safety concerns, and reliability concerns.

Plan 1 includes building two new substations supplied from the 115kV transmission system. System rearrangement proposed within this plan reduces loading and dependence on the 23kV sub-transmission system. The following are the major modifications proposed:

- Replace the out of phase 23/12.47kV substation at Phillipsdale with a new 115/12.47kV station. Initial construction would consist of a single 40MVA LTC transformer, straight-bus metal-clad switchgear, four feeder positions, and a 7.2MVAR two-stage capacitor bank. The ultimate build-out would be two 40MVA LTC transformers supplying straight-bus metal-clad switchgear with a tie breaker, eight feeder positions, and two 7.2MVAR two-stage capacitor banks.
- Build a new 115/12.47kV substation in the city of East Providence on a gas company owned land parcel adjacent to the 115kV transmission right-of-way. Initial construction would consist of a single 40MVA LTC transformer, straight-bus metal-clad switchgear, four feeder positions, and a 7.2MVAR two-stage capacitor bank. The ultimate build-out would be two 40MVA LTC transformers supplying straight-bus metal-clad switchgear with a tie breaker, eight feeder positions, and two 7.2MVAR two-stage capacitor banks.
- Expand the existing 115/12.47kV substation at Warren by installing two new 12.47kV distribution feeder positions and a two-stage 7.2MVAR capacitor bank on each bus.

The Plan 1 total cost estimate (over all years) is \$37.70M (\$31.68M capex, \$2.14M opex, \$3.88M removal).

Plan 2 includes adding new distribution capacity supplied from an upgraded 23kV sub-transmission system and has limited investment in expansion of the 115kV transmission system. The following are the major modifications proposed:

- Replace the existing 23/4.16kV substation at Kent Corners with two 23/12.47kV modular feeders supplied from an upgraded 23kV system. The sub-transmission upgrades require approximately 7.50 miles of line reconductoring along a public roadway system.
- Build two new 23/12.47kV modular feeders on a Company owned site in East Providence. This was the location of Rumford substation which was retired and removed in the 1990's.
- Replace the existing out of phase 23/12.47kV substation at Phillipsdale with two new 23/12.47kV modular feeders. The new feeders would phase with the rest of the distribution system in the area.
- Build a new 115/23kV substation at Mink Street to supply the reinforced, upgraded, and expanded 23kV system. Construction would consist of a single 40MVA transformer supplying a single 23kV line.
- Address asset condition concerns at Phillipsdale and Warren 115/23kV substations. These two stations, along with Mink Street, will supply the 23kV system.

The Plan 2 total cost estimate (over all years) is \$50.00M (\$42.29M capex, \$3.19M opex, \$4.52M removal).

Plan 3 is a hybrid of Plan 1 and Plan 2. It includes expanding the 115kV transmission system along with expanding and reinforcing the 23kV sub-transmission system. The following are the major modifications proposed:

- Replace the existing out of phase 23/12.47kV substation at Phillipsdale with a new 115/12.47kV station. Initial construction would consist of a single 40MVA LTC transformer, straight-bus metal-clad switchgear, four feeder positions, and a 7.2MVAR two-stage capacitor bank. The ultimate build-out would be two 40MVA LTC transformers supplying straight-bus metal-clad switchgear with a tie breaker, eight feeder positions, and two 7.2MVAR two-stage capacitor banks.
- Build a new 115/23kV substation at Mink Street to supply the reinforced, upgraded, and expanded 23kV system. Construction would consist of a single 40MVA transformer supplying a single 23kV line.
- Replace the existing 23/4.16kV substation at Kent Corners with two 23/12.47kV modular feeders supplied from an upgraded 23kV supply system. The sub-transmission upgrades require approximately 7.50 miles of line reconductoring along a public roadway system.
- Address asset condition concerns at Warren 115/23kV substation. This station, along with Mink Street, will supply the 23kV system.

The Plan 3 total cost estimate (over all years) is \$41.20M (\$34.29M capex, \$2.45M opex, \$4.46M removal).

Plan 1 is recommended for implementation. It provides a comprehensive solution to address all the concerns in the study area at least cost. The total cost of Plan 1 is \$37.70M which is \$13.00M lower in cost than Plan 2 and \$3.50M lower in cost than Plan 3.

Plan 1 is least sensitive to load growth and offers the most flexibility for future expansion. Plan 1 eliminates most of 23kV sub-transmission system installed along public roadways which has significant exposure to motor vehicle accidents and tree related outages. Plan 2 and Plan 3 offer no economic or reliability benefits over Plan 1 and are more sensitive to higher than forecasted load growth.

2. Introduction

2.1 Purpose

A comprehensive study of the East Bay area was performed to identify existing and potential future distribution system performance concerns. System evaluation included comparison of equipment loading to thermal (capacity) limits, contingency response capability (Distribution Planning Criteria), voltage performance (RI PUC requirements), breaker operating capability, arc flash review, reactive compensation performance, asset condition, and safety and environmental issues. The recommendations provide a comprehensive solution to address all the system performance concerns existing and anticipated in the study area thru 2030.

2.2 Problem

A study's initial system assessment is typically based on the needs identified through the Annual Planning process. The latest Annual Planning review showed a variety of normal and contingency capacity issues in the East Bay Area. Furthermore, informal asset condition reviews and inspection results indicated there may be growing asset condition concerns.

3. Background

3.1 Scope

3.1.1 Geographic Scope

The East Bay study area consists of the city of East Providence and the towns of Barrington, Bristol, and Warren. The study area is bounded to the east by the Commonwealth of Massachusetts, to the north by the City of Pawtucket, and to the west and south by the Providence River. The study area is shown geographically in Appendix 9.1.

3.1.2 Electrical Scope

Three 115kV transmission lines supply the load in the study area. Two lines, E-183E and F-184, originate at Brayton Point substation and one line, X-3, originates at Somerset substation. The study area has an extensive sub-transmission system consisting of five 23kV lines (2242, 2243, 2267, 2291, and 2295). One line diagrams are shown in Appendix 9.2.

Three 115/12.47kV substations (Bristol, Wampanoag, and Warren) supply approximately 115MW of area load. The remainder of the load, or approximately 63MW, is supplied from the 23kV sub-transmission system originating at Warren, Phillipsdale, and Mink Street substations. There is a small pocket of 4.16kV load, approximately 7.3MW, supplied from Kent Corners substation. Nine industrial customers are supplied directly from the 23kV sub-transmission system.

Mink Street, located in Massachusetts, has a 115/23/13.2kV 3-winding transformer that supplies both a 23kV line and a 13.2kV station. The 23kV line only supplies customers in Rhode Island. Mink Street is the only station located outside the study area that supplies East Bay customers.

3.2 Area Load and Load Forecast

The study area has approximately 43,000 customers with a peak electrical demand of 178MW. The study area is summer peaking and summer limited. This study used the most recent forecast developed by National Grid, the “2014 New England Electric Peak Forecast”. It utilized the 95/5 extreme weather scenario case. Table 1 shows the forecasted load growth rate for the study area from 2015 to 2030.

TABLE 3.2 – Forecasted Load Growth Rate from 2015 to 2030 for Study Area

Forecasted Growth – East Bay					AVG	AVG
2015	2016	2017	2018	2019	'20 to '23	'24 to '30
2.3%	1.4%	1.0%	0.6%	0.7%	0.7%	0.8%

3.3 Active Projects

Two active transmission studies were reviewed to determine potential impacts on the East Bay study area infrastructure and the plans being considered in this study.

The Southeastern Massachusetts and Rhode Island (SEMA/RI) study is expected to address transmission supply constraints in the southeastern Massachusetts and Rhode Island areas which includes the East Bay area. The results from this transmission study are not expected to impact any of the improvements being proposed in the East Bay Area Study.

The state of Rhode Island has requested the company investigate the feasibility of undergrounding the E-183W transmission line from the Phillipsdale substation tap in East Providence to Franklin Square substation in Providence. One option identified is the installation of a transition structure for this 115kV line on the site being considered for a proposed East Providence substation. A preliminary review has not identified any major concerns with the site’s ability to accommodate both projects.

3.4 Limitations on Infrastructure Development

The study area is an electrical island. It is bounded to the east by the Commonwealth of Massachusetts with a 13.2kV distribution system, to the north by the City of Pawtucket with a 13.8kV distribution system, and to the west and south by the Providence River. The study area is shown geographically in Appendix 9.1.

3.5 Assumptions & Guidelines

The current Distribution Planning Guide rev 1, February 2011 (“DPG”) was used when performing this study. The guide describes the normal and contingency analysis, as well as considerations for safety, the environment, reliability, reactive compensation, load balance, voltage, and efficiency, used in National Grid’s distribution planning studies.

The Distribution Planning & Asset Management department uses the Siemens PTI PSS/e loadflow program to analyze the transmission and sub-transmission system. This is the same program that is used by ISO NE and the National Grid Transmission Planning department.

The CYMdist 5.04 Revision 5.0 program was used to analyze radial three-phase unbalanced systems (distribution feeders). Databases are extracted from the GE-SmallWorld GIS System into a Microsoft Access format.

The ASPEN program was used to determine short circuit duty values at all substations.

4. Problem Identification

4.1 Thermal Loading

4.1.1 Normal Configuration - Thermal Loading

The distribution system in the East Bay area is heavily loaded with limited capacity to supply new load. Table 4.1.1 shows the projected feeder loading on the distribution system for the main limiting element of each circuit. Excluding the out of phase feeders and the small pocket of 4.16kV load, by 2020 approximately 50% of the feeders are projected to be loaded above 90% of SN rating. By 2026, 70% of the feeders are projected to be loaded above 90% of SN rating.

TABLE 4.1.1 - Projected Summer Normal Feeder Loading

Substation	Fdr	2020		2026		2028		2030	
		Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN
BARRINGTON	4F1	330	64%	344	67%	350	68%	355	69%
BARRINGTON	4F2	468	92%	488	96%	496	97%	504	99%
BRISTOL	51F1	519	81%	543	84%	552	86%	561	87%
BRISTOL	51F2	481	91%	503	95%	511	96%	520	98%
BRISTOL	51F3	431	86%	451	90%	458	91%	466	93%
WAMPANOAG	48F1	488	97%	512	102%	520	104%	528	105%
WAMPANOAG	48F2	445	86%	466	91%	474	92%	482	94%
WAMPANOAG	48F3	559	110%	585	115%	595	117%	604	119%
WAMPANOAG	48F4	542	102%	568	107%	577	109%	586	111%
WAMPANOAG	48F5	461	95%	483	100%	491	101%	498	103%
WAMPANOAG	48F6	420	79%	440	83%	447	84%	455	86%
WARREN	5F1	379	89%	392	92%	398	94%	404	95%
WARREN	5F2	396	91%	411	95%	416	96%	422	97%
WARREN	5F3	393	76%	407	79%	413	80%	419	81%
WARREN	5F4	466	91%	483	95%	490	96%	496	97%
OUT OF PHASE FEEDERS									
PHILLIPSDALE	20F1	336	79%	352	83%	358	84%	363	85%
PHILLIPSDALE	20F2	398	94%	417	98%	424	100%	430	101%
WATERMAN AVE	78F3	263	64%	276	68%	281	69%	285	70%
WATERMAN AVE	78F4	248	61%	260	64%	264	65%	268	66%
4.16kV POCKET OF LOAD									
KENT CORNERS	47J2	336	82%	352	86%	358	88%	364	89%
KENT CORNERS	47J3	349	86%	366	90%	372	91%	378	93%
KENT CORNERS	47J4	382	94%	400	98%	406	100%	413	101%

Loading of distribution line sections of each feeder were analyzed using the CYME software. Minimal overloaded sections were identified as shown in Appendix 9.4.

There are no projected transformer or supply line normal configuration overloads within the study period.

4.1.2 Contingency Configuration - Thermal Loading

A contingency analysis was performed for all feeders in the study area. This analysis calculates a MWh ‘exposure’ or risk assuming a worst case component failure. The assumptions made for this analysis include:

- A one-hour response time before performing the first switching step to allow sufficient time for a crew to respond to the outage.
- Assumes 30-minutes to execute each additional switching step. This appears reasonable since the feeders in this area are relatively short.
- Assumes a failed component can be repaired within four hours. Some feeders have underground cable getaways which may require a longer repair time. Due to the fact that exposure is relatively small, a cable failure was not assumed in the calculations.
- Some feeders are double circuited on the same pole plant, primarily near the substation. Due to the fact that exposure is relatively small, a failure involving two feeders was not assumed in the calculations.
- The MWh calculations utilize the summer emergency ratings of the feeders.

Table 4.1.2 below shows the MWh exposure for each study area feeder and any remaining unserved load. Because the feeders are heavily loaded, nearly all exceed the MWh exposure recommended in the DPG. The DPG recommends mitigating any exposure in excess of 16MWh.

TABLE 4.1.2 - Calculated MWh exposure and Un-Served Load on Feeders

Substation	Feeder	MWh	Un-Served
		Exposure	MW
BARRINGTON 4	4F1	18.2	3.45
BARRINGTON 4	4F2	22.7	2.91
BRISTOL 51A	51F1	24.7	2.36
BRISTOL 51A	51F2	25.2	4.06
BRISTOL 51A	51F3	21.1	2.52
WAMPANOAG 48	48F1	25.6	4.25
WAMPANOAG 48	48F2	23.5	4.52
WAMPANOAG 48	48F3	29.3	3.80
WAMPANOAG 48	48F4	42.0	10.31
WAMPANOAG 48	48F5	21.6	2.89
WAMPANOAG 48	48F6	26.2	5.15
WARREN 5	5F1	19.4	3.47
WARREN 5	5F2	24.5	5.00
WARREN 5	5F3	22.6	4.18
WARREN 5	5F4	21.0	0.99
WATERMAN AVENUE 78	78F3*	5.4	0.00
WATERMAN AVENUE 78	78F4*	5.3	0.00
PHILLIPSDALE 20	20F1*	23.9	5.67
PHILLIPSDALE 20	20F2*	13.6	1.08

* NOTE: These feeders are not in-phase with the remainder feeders. Any switching involving these feeders will require customers to be exposed to a short duration outage.

There are no MWh exposure issues above guidelines¹ for the station transformers and subtransmission system. However, one contingency load-at-risk issue involving the supply from the Mink Street substation should be noted. Mink Street is a low-profile station with two transformers. This station is located in Seekonk, MA, but includes a three-winding power transformer with a 23kV tertiary winding supplying East Bay area load. Peak loading on the 23kV winding is limited to 12MVA because capacity is needed to supply the Massachusetts 13.2kV load. This limit results in approximately 14MW of un-served load for loss of the preferred supply to Barrington substation and limits the ability to add load to the 23kV system. A one line on Mink Street is shown in Appendix 9.2.

4.2 Voltage Performance

The PSS/e load flow program was utilized to model the electrical system to the 23kV sub-transmission level including step-down transformers to the distribution feeder level. The DPG recommends that customer service voltages be maintained to meet ANSI 84.1 guidelines. ANSI 84.1 requires that service voltages be maintained between 0.95 and 1.05 per unit during normal loading conditions and between 0.90 and 1.10 per unit during contingency conditions. Because of the ability to adjust transformer tap settings and with existing voltage regulation equipment, the supply system can vary greater than the required service voltage range. However for study purposes, the supply system is screened for potential issues using the ANSI 84.1 ranges. No

¹ The Distribution Planning Guide, dated Feb 2011, recommends mitigation of station transformer and subtransmission contingency issues when the load-at-risk exceeds 240 MWh.

voltage issues were identified during this screening effort. See Appendix 9.3 for loadflow diagrams.

The CYME program models all three phases of each distribution feeder for its entire length starting at the substation. Voltages at all points should be maintained between the range of 0.95 to 1.05 per unit, or from 114 volts to 126 volts on a 120 volt base. Minor violations were identified but these violations can be corrected through minor feeder balancing. See Appendix 9.4 for CYME diagrams.

4.3 Asset Condition

Asset condition reviews were conducted at each substation within the study area.

Mink Street is a low-profile station with two transformers. This station is located in Seekonk, MA, but includes a three-winding power transformer with a 23kV tertiary winding supplying East Bay area load. The asset condition review (for this study's purposes) is limited to this three-winding transformer and there are no immediate issues.

Barrington is a 23/12.47kV substation with a single transformer supplying two feeders with approximately 17MW of peak load. Appendix 9.2 shows a one-line of the station. A number of concerns exist at this station:

- The sacrificial air break (1T23) on the 25MVA power transformer does not provide adequate protection and results in an elevated risk of transformer failure.
- The station bus does not comply with current minimum clearance requirements. Jersey barriers are currently used to prevent accidental contact as a temporary measure.
- The 4F2 recloser is no longer reliable. This recloser has been identified for replacement in the ARP.
- This station has no remote status, control and monitoring of all switching devices, transformers, voltage regulation and battery systems (no EMS).

Kent Corners is a 23/4.16kV substation supplying 7.3MW of peak load. Appendix 9.2 shows a one-line of the station. This station is the only 4.16kV station left in the area. It is a 1950's vintage station with mostly original equipment. A number of concerns exist at this station:

- The circuit breakers are no longer reliable.
- The 23kV air-break motor operators and live parts are obsolete and require custom made parts to continue to maintain these air-breaks.
- The station power transformers are 1950's vintage. Parts for transformer bushings are no longer manufacturer supported.
- There have been neighborhood complaints about transformer noise. Station is located in a heavily congested residential neighborhood.
- This station has no remote status, control and monitoring of all switching devices, transformers, voltage regulation and battery systems (no EMS).

The Phillipsdale 115/23kV substation supplies two 23/12.47kV stations and a number of industrial customers with a combined peak load of approximately 30MW. Appendix 9.2 shows a one-line of the station. A number of concerns exist at this station:

- The power transformers are 1960's vintage. T1 transformer is the only transformer in the system with attached coolers. T2 transformer shows significant signs of aging and has been identified for replacement in the ARP. Replacement of the T2 transformer has been deferred pending completion of this study.
- Transformer grounding reactors are concrete encased with small visible cracks. There is no spare grounding reactor to respond to a failure.
- Transformer 23kV disconnect switches are non-gang operated and are not readily accessible to operate.
- The 23kV breakers are no longer reliable.
- The transformer and bus arrestors are obsolete.
- A timed scheme at the station prevents bus ties from occurring unless disabled. This scheme is complex to operate.

The Phillipsdale 23/12.47kV substation consists of non-standard equipment and construction. Appendix 9.2 shows a one-line of the station. A number of concerns exist at this station:

- A single LTC transformer supplies two 12.47kV feeders with pole mounted line reclosers. The reclosers have a history of poor reliability.
- The distribution voltage from this station only phases with Waterman Avenue feeders. This results in a pocket of load being out of phase with the rest of the system and makes maintenance of the station equipment challenging.
- The LTC transformer is a delta/zig-zag with no system spare and only a single mobile transformer in the system suitable for this location. A transformer failure would tie up this mobile for an extended period.

The Warren 115/23kV station consists of two 30/40/50 MVA transformers supplying two 23kV lines with approximately 34MW of peak load. Appendix 9.2 shows a one-line of the station. A number of concerns exist at this station:

- The 23kV breakers have reliability concerns.
- The pin type insulators on the 23kV bus are obsolete.
- The 23kV protection is located in an old control house with electro-mechanical relays. Most of this protection is obsolete.
- There are obsolete GE Butyl Rubber PT's
- The RAPR system is obsolete.

The Waterman 23/12.47kV station is located just north of Wampanoag substation. It consists of two 10/12.5 MVA transformers supplying four feeders. Appendix 9.2 shows a one-line of the station. Only two Waterman feeders supply customer load because the other two feeders are landlocked by Wampanoag substation to the south. In addition, these two feeders only phase with Phillipsdale feeders which creates a pocket of out-of phase load in the area. A number of concerns exist at this station:

- The 23kV air-break switch is obsolete.
- The transformers have sacrificial high side air breaks switches which are obsolete.
- The 23kV capacitor bank has an obsolete VBM switch.
- The 23kV equipment is mounted on wood poles.

Most of the 23kV sub-transmission system consists of aged pole plant and small wire installed on congested public roadways. A one-line of the 23kV supply system is shown in Appendix 9.2. Only a small portion of this system has been rebuilt in the last 20-years. The remainder of the system consists of a mixture of 795 Al, 336.4Al, 2/0Cu, and 1/0Cu wire with 12.47kV under-build. A major investment to replace both the pole plant and wire size would be required to increase the capacity of this system.

4.4 Additional Analysis

4.4.1 Reliability Performance

A reliability review was conducted to check feeder indices against system targets. For calendar year 2014, the SAIFI target was 1.05 and SAIDI target was 71.9 minutes. No three year trends were identified requiring further reliability analysis. See Table 4.4.1 below.

TABLE 4.4.1 – Study Area Reliability Indices

FEEDER	2014		2013		2012	
	CKAIFI	CKAIDI	CKAIFI	CKAIDI	CKAIFI	CKAIDI
53-20F1	1.019	101.75	3.122	112.71	0.045	0.27
53-20F2	1.063	139.31	1.243	82.38	0.159	18.04
53-47J2	0.003	0.29	0.291	5.88	0.025	6.82
53-47J3	0.106	4.64	0.000	0.00	0.051	6.73
53-47J4	0.011	0.72	0.098	7.23	0.103	15.25
53-48F1	0.157	6.75	0.039	4.06	0.891	54.20
53-48F2	1.055	100.74	0.136	33.91	2.436	123.97
53-48F3	0.056	5.28	0.139	15.59	1.661	160.22
53-48F4	0.040	5.47	0.109	9.97	0.077	20.58
53-48F5	0.064	7.10	0.143	23.63	0.073	6.94
53-48F6	0.071	7.35	0.059	4.20	0.504	30.07
53-4F1	0.215	28.54	1.151	90.14	1.016	96.34
53-4F2	0.333	26.31	1.861	106.53	1.339	131.67
53-51F1	0.623	103.16	0.189	24.17	0.143	11.33
53-51F2	0.239	18.33	0.086	5.70	0.160	6.38
53-51F3	0.227	17.55	1.088	97.15	0.428	19.07
53-5F1	2.040	130.98	1.468	98.81	0.259	28.43
53-5F2	0.209	16.38	0.245	79.90	2.716	196.41
53-5F3	0.110	5.02	0.342	82.02	1.767	232.77
53-5F4	0.225	49.33	1.178	79.47	1.197	285.36
53-78F3	0.073	14.81	0.850	50.80	0.083	8.11
53-78F4	1.254	81.31	0.045	2.70	0.040	3.27

4.4.2 Arc Flash

On April 1, 2014, the United States Department of Labor’s Occupational Safety and Health Administration (“OSHA”) issued final rule 1910.269 requiring the employer to assess the workplace to identify employees exposed to hazards from flames or electric arcs. 1910.269 proposed compliance dates of January 1, 2015 and April 1, 2015 for completion of the hazard assessment and implementation of the assessment results respectively. As the industry adjusted to these new requirements and calculation methods, the dates were adjusted to March 31, 2015 and August 31, 2015.

As described above arc flash regulations were issued and analysis methods were reviewed and adjusted during the course of this study. A review using CYME fault current analysis and protection coordination values with ArcPro incident energy calculations provided an analysis in compliance with OSHA requirements. Appendix 9.5 shows the results of this analysis with no study area feeders indicating incident energies above 8 calories per centimeter squared (cal/cm²).

4.4.3 Fault Duty/Short Circuit Availability

The ASSEN program was used to calculate single phase to ground and three phase short circuit duty values at each area substation. These values were compared to the station breaker interrupting capabilities. The table in Appendix 9.6 summarizes the results of this analysis. No breakers in the study area were identified to have a short circuit duty exceeding their interrupting capability.

4.4.4 Reactive Compensation

ISO-NE conducts an annual survey of actual load power factor operations and compares it against the applicable standards. The latest survey has this overall area compliant at all times. The results of this survey are shown on Table 4.4.4 below:

TABLE 4.4.4: ISO-NE Power Factor Survey Results

	CURRENT LFP SURVEY SUMMARY						COMPLIANCE REPORT					
	Spring	Summer		Fall	Winter		Spring	Summer		Fall	Winter	
	9,195	22,177	27,360	9,271	18,180	21,448	9,195	22,177	27,360	9,271	18,180	21,448
	5/19/13	08/21/2013	07/19/13	9/29/13	12/4/13	12/17/13	5/19/13	08/21/2013	07/19/13	9/29/13	12/4/13	12/17/13
	4:00	18:00	17:00	5:00	18:00	18:00	4:00	18:00	17:00	5:00	18:00	18:00
Narragansett	0.983	0.997	0.995	0.983	0.998	0.999	compliant	compliant	compliant	compliant	compliant	compliant

The power factor performance of the study area’s feeders is limited to those that have PI data availability. This includes only the 12.47kV feeders at Warren substation. Peak power factor performance for these feeders shows them to be near unity or leading, indicating adequate feeder reactive support. Available data for major 115kV transformer interfaces and the 23 kV sub-transmission lines also show power factor near unity or slightly lagging.

5. Plan Development

5.1 Consideration of Distributed Generation in Plan Development

The impact of existing and planned distributed generation (“DG”) installations were considered in the plan formulation. Installations of significant size (greater than 1 MW) appear on one 23 kV

sub-transmission line (2267 line). There are two solar array sites on this line, one existing and one proposed, each sized at 3 MWs. Appendix 9.11 lists the existing and proposed DG within the study area.

The DG was analyzed from a hypothetical peak reduction perspective. Peak contribution factors, the ratio of the megawatts generated on peak versus the nameplate rating of the generator, can vary greatly on a daily or yearly basis as a result of location, weather, and other factors. Observing the 2014 summer data for the in-service solar array shows peak contribution factors of 77%, 40%, 23%, and 10% for 12:00PM, 3:00PM, 4:00PM, and 6PM respectively. Using a conservatively high peak contribution factor of 30% of nameplate, results in a possible peak reduction of 1.8 MW for the existing and proposed DG. This equates to approximately 45 amps at 23kV. There are no projected sub-transmission normal configuration overloads predicted in the study period. This peak reduction analysis resulted in no impact to the proposed plans.

Area DG was also analyzed from a comprehensive study-wide perspective. All area stations, except Wampanoag, have contingency load-at-risk issues and asset conditions issues (see Sections 4.1.2 and 4.3). The existing and proposed DG does not address or avoid necessary asset condition issues and is not significant or dependable in load levels to mitigate capacity issues. As a result, the comprehensive plans are also unaffected by the existing or proposed distributed generation.

5.2 Common Items

The Bristol/Warren area is electrically isolated from the East Providence/Barrington area. There are no feeder ties between these areas because of the Barrington River. The river forms a natural barrier that makes feeder ties between the areas neither practical nor economical.

Although there are no thermal concerns to resolve in the Bristol/Warren area, the feeders are highly utilized resulting in contingency load-at-risk exceeding the DPG guidelines. To resolve this issue, the following investments are recommended.

- Install a new feeder, 51F4, at Bristol substation. A one-line of the proposed work is shown in Appendix 9.7.
- Upgrade the thermal capability of the Warren 5F2 and 5F4 feeders. This involves upgrading the front end of both circuits.

The investments and expenses for the common items are shown in Table 5.2 below:

TABLE 5.2 - Estimated Cost of Common Items (\$M)

Description	Capex	Opex	Removal	Total
East Bay Common Item (D-Sub)	\$0.590	\$0.075	\$0.005	\$0.670
East Bay Common Item (D-Line)	\$0.620	\$0.042	\$0.153	\$0.815
TOTAL (COMMON)	\$1.210	\$0.117	\$0.158	\$1.485

5.3 Plan – 1

This plan includes building two new substations supplied from the 115kV transmission system. System rearrangement proposed within this plan reduces loading and dependence on the 23kV sub-transmission system. The following are the major modifications proposed:

Construct a new 115/12.47kV Station at Phillipsdale:

Build a new 115/12.47kV substation at Phillipsdale. Initial construction would consist of a single 40MVA LTC transformer, straight-bus metal-clad switchgear, a 7.2 MVAR station capacitor bank, and four feeder positions. The ultimate build-out would be two 40MVA LTC transformers supplying straight-bus metal-clad switchgear with a tie breaker, two 7.2MVAR capacitor bank, and eight feeder positions. A one line of this proposed station is shown in Appendix 9.8. The station would be supplied from the 115kV lines, X-3 and E-183W. The four new feeders from this station would:

- Replace the 23/12.47kV non-standard construction at Phillipsdale substation with standard station equipment, address the asset condition concerns, and provide capacity to supply new customers in the northern section of the City of East Providence.
- Eliminate out of phase feeder ties by correcting the voltage phasing. This would increase switching flexibility, reduce restoration time, and improve reliability since customers would not be exposed to short outages during switching.
- Retire Waterman substation to address asset condition concerns, eliminate the need for a major investment to upgrade the 23kV supply system, and eliminate the out of phase feeder ties that exist at Waterman.
- Reduce load on the 115/23kV station at Phillisdale from 30MW to 3MW. The long-term strategy would be to convert the two remaining 23kV customers to 12.47kV and retire the 23kV station. This approach eliminates a major investment on the 23kV station to address the asset condition and obsolete equipment concerns.

The new feeders would be routed on public roadways in new manhole and ductline infrastructure. Five industrial customers would be converted from 23kV to 12.47kV which would reduce load on the 23kV system, eliminate circuits installed in a difficult to access right-of-way adjacent to the railroad corridor, and eliminate a major investment to address the poor condition of the pole plant along this 23kV right-of-way.

The customers to be converted to 12.47kV are: Hasbro with (3) 500kVA transformers; Handy Harmon with (3) 667kVA transformers; Cape Cod Ice with (3) 333kVA transformers; BA Ballou with (3) 500kVA transformers; and Nyman Manufacturing which is primary metered customer with a peak demand of 1.70MW.

Construct a new 115/12.47kV Station in East Providence:

Build a new 115/12.47kV substation on First Street in East Providence on a gas company owned parcel next to the 115kV transmission right of way. Initial construction would consist of a single 40MVA LTC transformer, straight-bus metal-clad switchgear, a 7.2 MVAR station capacitor bank, and four feeder positions. The ultimate build-out would be two 40MVA LTC transformers

supplying straight-bus metal-clad switchgear with a tie breaker, two 7.2MVAR capacitor banks, and eight feeder positions. A one line of this proposed station and the site plan is shown in Appendix 9.8. The station would be supplied from the 115kV line, E-183W. The four new feeders from this station would:

- Provide capacity to relieve the heavily loaded distribution feeders in the area, address MWh violations, and provide capacity to supply load growth.
- Retire Kent Corners 23/4.16kV substation. This retirement would address the only remaining pocket of 4.16kV load in the area and is a component of a comprehensive plan to eliminate the need for a new 115/23kV station at Mink St.
- Be a component of a comprehensive approach that eliminates the need for a major upgrade of the 23kV supply system. The sub-transmission upgrades would require approximately 7.50 miles of line reconductoring along a public roadway system.

The four new feeders would be routed on public roadways in new manhole and ductline infrastructure. Kent Corners 4.16kV load would be converted to the 12.47kV system thru direct conversions and the use of step-down transformers to reduce cost. One industrial customer and a solar generator would be converted from 23kV to 12.47kV. The conversion of these customers is required to provide routes for the new 12.47kV feeders.

Add two new feeders at Warren Substation:

Expand Warren 115/12.47kV substation by adding two new distribution feeders and two 7.6MVAR station capacitor banks. The new feeders would be routed into Barrington and be used to retire Barrington substation. A one line of the proposed station expansion is shown in Appendix 9.8. This investment would address the asset and safety concerns at Barrington substation, eliminate the need for a new 115/23kV station at Mink Street, and eliminate the need for major upgrades on the 23kV supply system.

Substation Retirements:

The final component of this plan is to retire a number of substations in the study area and remove all equipment and foundations to below grade. The stations retirements are Mink Street 23kV station; Barrington substation; Kent Corners substation; Phillipsdale 23/12.47kV substation; Waterman substation; and retire the 2291 Line position at Warren substation. These substation retirements are part of a comprehensive plan to address all the issues in the study area at least cost.

The proposed mainline distribution for Plan 1 is shown in Appendix 9.8. The investments and expenses for Plan 1 are detailed in Table 5.3 below.

TABLE 5.3 - Estimated Investments and Expenses for Plan 1

Investment Description (\$M)	Capex	Opex	Removal	Total
Phillipsdale Substation (T-Line)	\$0.400	\$0.020	\$0.010	\$0.430
Phillipsdale Substation (T-Sub)	\$0.300	\$0.000	\$0.000	\$0.300
Phillipsdale Substation (D-Line)	\$3.716	\$0.064	\$0.260	\$4.040
Phillipsdale Substation (D-Sub)	\$6.020	\$0.600	\$0.380	\$7.000
East Providence Substation (T-Line)	\$0.400	\$0.000	\$0.000	\$0.400
East Providence Substation (T-Sub)	\$0.300	\$0.000	\$0.000	\$0.300
East Providence Substation (D-Line)	\$7.371	\$0.405	\$1.424	\$9.200
East Providence Substation (D-Sub)	\$6.020	\$0.550	\$0.030	\$6.600
Warren Substation (D-Line)	\$3.700	\$0.100	\$0.350	\$4.150
Warren Substaion (D-Sub)	\$3.450	\$0.290	\$0.175	\$3.915
Mink Street Retirement (D-Sub)	\$0.000	\$0.020	\$0.220	\$0.240
Barrington Sub Retirement (D-Sub)	\$0.000	\$0.030	\$0.345	\$0.375
Kent Corners Sub Retirement (D-Sub)	\$0.000	\$0.030	\$0.345	\$0.375
Waterman Sub Retirement (D-Sub)	\$0.000	\$0.030	\$0.345	\$0.350
Plan 1 (T-Spend)	\$1.400	\$0.020	\$0.010	\$1.430
Plan 1 (D-Spend)	\$30.277	\$2.119	\$3.874	\$36.270
Total Spend	\$31.677	\$2.139	\$3.884	\$37.700

5.4 Alternative Plans

5.4.1 Plan – 2

This plan includes adding new distribution capacity supplied from an upgraded 23kV sub-transmission system and has limited investment in expansion of the 115kV transmission system. The following are the major modifications proposed:

Install two new 23/12.47kV Feeders at Phillipsdale substation

This alternative would build two new 23/12.47kV modular feeders at Phillipsdale substation. The new feeders would be used to retire the existing non-standard construction that currently exists at Phillipsdale and would correct the out-of-phase feeder ties. A one-line of the proposed station is shown in Appendix 9.9.

The existing 115/23kV station at Phillipsdale would supply the new modular feeders requiring the asset condition issues described in Section 4.3 to be addressed. The 1960's vintage power transformer would be replaced with 40 MVA transformers to address the reliability concerns. The 23kV breakers would be replaced along with the obsolete bus and transformer arrestors. The electromechanical relays would be upgraded with modern solid state relays. The timed bus tie scheme would be removed and EMS would be installed.

Install two new 23/12.47kV Feeders at Rumford substation

Plan 2 would install two new 23/12.47kV modular feeders at the former Rumford substation site located at 127 North Broadway in East Providence. Feeders would be supplied from the 115/23kV station at Phillipsdale. Access to the right-of-way along the railroad corridor would be improved and the obsolete pole plant would be replaced. A one-line of the proposed station is shown in Appendix 9.9.

The new Rumford substation feeders would provide capacity to supply new load growth, address MWh violations, and be used to retire Waterman Ave substation. The new feeders would also correct out-of-phase feeder ties, eliminate the need for asset replacement work at Waterman Ave substation, relocate the station away from Wampanoag substation, and move the station to a more robust 23kV supply system.

Waterman substation feeders are landlocked to the south by Wampanoag substation and the 23kV supply consists of small wire and aged pole plant that does not meet current standards for 23kV construction. As such, there is no economic or reliability benefit to maintaining Waterman Ave substation in its current location.

Install two new 23/12.47kV Feeders at Kent Corners substation

Plan 2 would install two new 23/12.47kV modular feeders at Kent Corners substation. The new feeders would provide capacity to relieve the heavily loaded distribution system in the area, address contingency load-at-risk issues, and provide capacity to supply new load growth. Investment would also eliminate the small pocket of 4.16kV load in the study area by retiring the existing Kent Corners 23/4.16kV station. A one-line of the proposed station is shown in Appendix 9.9.

Build a New 115/23kV Substation at Mink Street²

A new 115/23kV substation would be built at Mink Street to supply Kent Corners and Barrington substations. Construction would consist of a single 40MVA transformer supplying a single 23kV line. The station would be supplied by an existing 115kV line at Mink Street. A one-line of the proposed station is shown in Appendix 9.9.

Address Concerns at Barrington Substation

Plan 2 would address asset and safety concerns with Barrington substation. The sacrificial air break on the station transformer would be replaced with a circuit switcher, the bus work and taps would be raised to comply with current standards, the 4F2 VSA recloser would be replaced to address asset condition concerns and EMS would be installed at the station.

Upgrade and Reinforce the 23kV Sub-Transmission System

The 23kV sub-transmission system from Mink Street consists of a mixture of 336 Al, 2/0 Cu and 1/0 Cu wire. This system is not adequate to supply the proposed Kent Corners and Barrington substations. To supply these stations the small wire would have to be replaced with 795 Al open wire. Construction would consist of approximately 7.5 miles of double circuited roadway infrastructure along highly utilized and congested public roadways. This would require replacement of all the aged pole plant to meet current standards and to accommodate the larger wire size.

The normal supply to Barrington substation would be from the Warren 115/23kV station, a station with numerous asset condition concerns. As part of this plan, the asset condition concerns at Warren would be addressed. The 23kV breakers would be replaced along with all the obsolete pin type bus insulators. The obsolete protection would be upgraded and relocated from the old control house to the new control house. A one line of the proposed 23kV supply system is shown in Appendix 9.9.

This plan results in a comprehensive solution for the East Bay area and addresses all asset condition, safety, and reliability concerns. Plan addresses all thermal concerns, provides capacity to supply load growth, and addresses all distribution planning criteria violations. The required investments and expenses for Plan 2 are detailed in Table 5.4.1 below.

² Mink Street 115/23kV substation will be located in Massachusetts and supply customers in Rhode Island. It will be built, owned, and operated by the New England Power Company (NEPCo). An appropriate rate recovery mechanism needs to be developed. Rate recovery could occur thru a Transmission Rate Tariff or thru a Direct Assignment Charge. A Local Service Agreement may also need to be filed with the Federal Energy Regulatory Commission (FERC). If this plan were to be implemented, the legal department will be consulted to determine the most appropriate rate recovery mechanism for these assets.

TABLE 5.4.1 - Estimated Investments and Expenses for Plan 2

Investment Description (\$M)	Capex	Opex	Removal	Total
Mink St Substation (T-Line)	\$0.500	\$0.000	\$0.000	\$0.500
Mink St Substation (T-Sub)	\$3.500	\$0.020	\$0.220	\$3.740
Phillipsdale Substation (T-Sub)	\$9.000	\$0.600	\$0.080	\$9.680
Phillipsdale Substation (D-Sub)	\$3.550	\$0.400	\$0.350	\$4.300
Phillipsdale Substation (D-Line)	\$2.250	\$0.050	\$0.160	\$2.460
Kent Corners Substation (D-Sub)	\$3.600	\$0.400	\$0.350	\$4.350
Kent Corners Substation (D-Line)	\$10.200	\$0.800	\$2.600	\$13.600
Rumford Substation (D-Sub)	\$3.600	\$0.360	\$0.000	\$3.960
Rumford Substation (D-Line)	\$1.450	\$0.050	\$0.400	\$1.900
Warren Substation (D-Sub)	\$2.835	\$0.300	\$0.025	\$3.160
Barrington Substation (D-Sub)	\$1.800	\$0.180	\$0.020	\$2.000
Waterman Sub (D-Sub)	\$0.000	\$0.030	\$0.320	\$0.350
Plan 2 (T-Spend)	\$13.000	\$0.620	\$0.300	\$13.920
Plan 2 (D-Spend)	\$29.285	\$2.570	\$4.225	\$36.080
Total Spend	\$42.285	\$3.190	\$4.525	\$50.000

5.4.2 Plan – 3

This plan is a hybrid of Plan 1 and Plan 2. It includes expanding the 23kV sub-transmission system to supply both existing and new 23/12.47kV distribution substations and includes expanding the 115kV system to supply a new 115/12.47kV station at Phillipsdale. The following are the major modifications proposed:

Construct a new 115/12.47kV Station at Phillipsdale

This option would build a new 115/12.47kV substation at Phillipsdale. Initial construction would consist of a single 40MVA LTC transformer, straight-bus metal-clad switchgear, a 7.2 MVAR station capacitor bank, and four feeder positions. The ultimate build-out would be two 40MVA LTC transformers supplying straight-bus metal-clad switchgear with a tie breaker, two 7.2MVAR capacitor banks, and eight feeder positions. A one line of this proposed station is shown in Appendix 9.10. The station would be supplied from the 115kV lines, X-3 and E-183W. The four new feeders from this station would:

- Replace the 23/12.47kV non-standard construction at Phillipsdale with standard substation equipment, address the asset condition concerns, and provide capacity to supply new customers in the northern section of the City of East Providence.
- Eliminate out-of-phase feeder ties by correcting the voltage phasing. This would increase switching flexibility, reduce restoration time, and improve reliability since customers would not be exposed to short outages during switching.
- Retire Waterman substation to address asset condition concerns, eliminate the need for a major investment to upgrade the 23kV supply system, eliminate the out-of-phase feeder ties that exist at Waterman, and eliminate the need to build a new 115/23kV station at Mink Street.
- Reduce load on the 115/23kV station at Phillisdale from 30MW to 3MW. The long-term strategy would be to convert the two remaining 23kV customers to 12.47kV and to retire the 23kV station. This eliminates a major investment on the 23kV station to address the asset condition and obsolete equipment concerns.

The new feeders would be routed along city streets in new manhole and ductline infrastructure. Five industrial customers would be converted from the 23kV system to the 12.47kV system. This conversion eliminates circuits installed in a difficult to access right-of-way adjacent to the railroad corridor, and eliminates a major investment to address the poor condition of the pole plant along this 23kV right-of-way.

The customers to be converted to 12.47kV are: Hasbro with (3) 500kVA transformers; Handy Harmon with (3) 667kVA transformers; Cape Cod Ice with (3) 333kVA transformers; BA Ballou with (3) 500kVA transformers; and Nyman Manufacturing which is primary metered customer with 1.70MW of peak.

Install two new 23/12.47kV Feeders at Kent Corners substation

Plan 3 would install two new 23/12.47kV modular feeders at Kent Corners substation. The new feeders would provide capacity to relieve the heavily loaded distribution system in the area, address MWh violations, and provide capacity to supply new load growth. Investment would also eliminate the small pocket of 4.16kV load in the study area by retiring the existing Kent Corners 23/4.16kV station. A one-line of the proposed station is shown in Appendix 9.10.

Build new 115/23kV Substation at Mink Street³

A new 115/23kV substation would be built at Mink Street to supply Kent Corners and Barrington substations. Construction would consist of a single 40MVA transformer supplying a single 23kV line. The station would be supplied by an existing 115kV line at Mink Street. A one-line of the proposed station is shown in Appendix 9.10.

³ Mink Street 115/23kV substation will be located in Massachusetts and supply customers in Rhode Island. It will be built, owned, and operated by the New England Power Company (NEPCo). An appropriate rate recovery mechanism needs to be developed. Rate recovery could occur thru a Transmission Rate Tariff or thru a Direct Assignment Charge. A Local Service Agreement may also need to be filed with the Federal Energy Regulatory Commission (FERC). If this plan were to be implemented, the legal department will be consulted to determine the most appropriate rate recovery mechanism for these assets.

Address Concerns at Barrington Substation

Plan 3 would address asset and safety concerns with Barrington substation. The sacrificial air break on the station transformer would be replaced with a circuit switcher, the bus work and taps would be raised to comply with current standards, the 4F2 VSA recloser would be replaced to address asset condition concerns and EMS would be installed at the station.

Upgrade and Reinforce the 23kV Sub-Transmission System:

The 23kV sub-transmission system from Mink Street consists of a mixture of 336 Al, 2/0 Cu and 1/0 Cu wire. This system is not adequate to supply the proposed Kent Corners and Barrington substations. To supply these stations the small wire would have to be replaced with 795 Al open wire. Construction would consist of approximately 7.5 miles of double circuited roadway infrastructure along highly utilized and congested streets. This would require replacement of all the aged pole plant to meet current standards and to accommodate the larger wire size.

The normal supply to Barrington substation would be from the Warren 115/23kV station, a station with numerous asset condition concerns. As part of this plan, the asset condition concerns at Warren would be addressed. The 23kV breakers would be replaced along with all the obsolete pin type bus insulators. The obsolete protection would be upgraded and relocated from the old control house to the new control house. A one line of the proposed 23kV supply system is shown in Appendix 9.10.

This plan results in a comprehensive solution for the East Bay area and addresses all asset condition, safety, and reliability concerns. Plan addresses all thermal concerns, provides capacity to supply load growth, and addresses all distribution planning criteria violations. The required investments and expenses for Plan 3 are detailed in Table 5.3.2 below.

TABLE 5.4.2 – Estimated Investments and Expenses for Plan 3:

Investment Description (\$M)	Capex	Opex	Removal	Total
Phillipsdale Substation (T-Line)	\$0.400	\$0.000	\$0.000	\$0.400
Phillipsdale Substation (T-Sub)	\$0.300	\$0.000	\$0.000	\$0.300
Phillipsdale Substation (D-Line)	\$4.430	\$0.120	\$0.545	\$5.095
Phillipsdale Substation (D-Sub)	\$6.020	\$0.600	\$0.380	\$7.000
Kent Corners Substation (D-Sub)	\$3.600	\$0.400	\$0.350	\$4.350
Kent Corners Substation (D-Line)	\$10.300	\$0.800	\$2.600	\$13.700
Mink St Substation (T-Line)	\$0.500	\$0.000	\$0.000	\$0.500
Mink St Substation (T-Sub)	\$3.500	\$0.020	\$0.220	\$3.740
Mink St Substation (D-Line)	\$0.600	\$0.000	\$0.000	\$0.600
Warren Substation (D-Sub)	\$2.840	\$0.300	\$0.025	\$3.160
Barrington Substation (D-Sub)	\$1.800	\$0.180	\$0.020	\$2.005
Waterman Sub (D-Sub)	\$0.000	\$0.030	\$0.320	\$0.350
Plan 1 (T-Spend)	\$4.700	\$0.020	\$0.220	\$4.940
Plan 1 (D-Spend)	\$29.590	\$2.430	\$4.240	\$36.260
Total Spend	\$34.290	\$2.450	\$4.460	\$41.200

5.4.3 Do Nothing

Taking no action would leave all the problems mentioned in Section 4 unaddressed. Violations of the Distribution Planning Criteria would continue to exist and worsen as time goes by, adversely affecting customer service and reliability performance.

Taking no action could make supplying new customer loads very challenging and could result in the company operating the system above its rated capability.

6. Plan Considerations and Comparisons

6.1 Economic, Schedule, and Technical Comparisons

The estimated investments and expenses for the three Plans are shown in Table 6.1 below. The economic comparisons exclude the cost of common items.

TABLE 6.1 – Estimated Investments and Expenses for Plan 1, Plan 2, and Plan 3

Description	PLAN 1				PLAN 2				PLAN 3			
	Capex	Opex	Rem.	Total	Capex	Opex	Rem.	Total	Capex	Opex	Rem.	Total
East Bay (T-Line)	\$0.80	\$0.02	\$0.01	\$0.83	\$0.50	\$0.00	\$0.00	\$0.50	\$0.90	\$0.00	\$0.00	\$0.90
East Bay (T-Sub)	\$0.60	\$0.00	\$0.00	\$0.60	\$12.50	\$0.62	\$0.30	\$13.42	\$3.80	\$0.02	\$0.22	\$4.04
East Bay (D-Sub)	\$15.50	\$1.52	\$1.85	\$18.87	\$15.29	\$1.67	\$1.13	\$18.08	\$14.29	\$1.53	\$1.14	\$16.96
East Bay (D-Line)	\$14.80	\$0.60	\$2.00	\$17.40	\$14.00	\$0.90	\$3.10	\$18.00	\$15.30	\$0.90	\$3.10	\$19.30
TOTAL	\$31.70	\$2.14	\$3.86	\$37.70	\$42.29	\$3.19	\$4.53	\$50.00	\$34.29	\$2.45	\$4.46	\$41.20

Plan 1 is least sensitive to load growth and offers the most flexibility for future expansion. It eliminates most of the 23kV supply system installed along the roadway and with significant exposure to motor vehicle accidents and tree related outages. It adds new distribution capacity supplied from a more reliable 115kV system with little exposure to motor vehicle accidents and tree related outages. It has flexibility to add additional distribution feeders with a minimal investment on the supply system and with minimal permitting.

Plan 2 is the most sensitive to load growth. It upgrades the 23kV system to supply new 23/12.47kV distribution stations. The 23kV supply upgrades would consist of predominantly highly congested roadway construction and be limited to 795 aluminum open wire, which limits the capacity to 35MVA. Once this capacity is reached, the only economical approach would be to utilize the 115kV transmission system to supply new distribution stations. The 23kV supply system would have exposure to motor vehicle accidents and tree related outages due to the roadway construction. Although beyond the 15 year study horizon, this plan only defers the eventual need to implement portions of Plan 1 once the capacity of the 23kV supply system is utilized.

Plan 3 is a hybrid of Plan 1 and Plan 2. It is less flexible than Plan 1 but more flexible than Plan 2. It installs a new station supplied from the 115kV system and new distribution capacity supplied from a reinforced 23kV system. The 23kV supply would consist of predominantly roadway construction and be limited to 795 aluminum open wire, which limits the capacity to 35MVA. As with Plan 2, once this capacity is reached, the only economical approach would be to utilize the 115kV system to supply new distribution stations. The 23kV supply system would have exposure to motor vehicle accidents and tree related outages due to the roadway construction.

6.2 Non-Wires Alternatives Considerations

Where an issue has been identified, a Non-Wires Alternative may also be considered as an option to defer a transmission, sub-transmission, or distribution wires solution for a period of time. Considering Non-Wires Alternatives to every wires solution is not practical given the low cost of a large volume of potential wires solutions, the magnitude of load relief required in certain situations, the time to acquire Non-Wires Alternatives (and verify their availability) or instances where the issue is poor operating condition of the asset. As a result, Non-wires Alternatives are screened against the following four guidelines:

- A. The Wires solution, based on Engineering judgment, will likely be more than \$1M;
- B. If load reduction is necessary, then it will be less than 20 percent of the total load in the area of the defined need;
- C. Start of construction is at least 36 months in the future; and
- D. The need is not based on Asset Condition.

Although the plans developed for this study will exceed \$1M and the start of construction for the majority of the work will be at least 36 months in the future, there are significant asset condition issues within the study area as described in Section 4.3. Therefore Non-Wires Alternatives are not considered feasible to provide a comprehensive study area solution.

However, a Non-Wires solution could be investigated to address the contingency load-at-risk issues in Bristol and Warren in lieu of installing a new feeder at Bristol substation and upgrading the feeders at Warren substation. This solution, common to all plans (see Section 5.1), does not have an asset condition component. Since this investment is recommended in the outer years of the study (see Section 7.0), it provides sufficient lead time to investigate the feasibility of a non-wires solution for the area.

6.3 Permitting, Licensing, Real Estate, and Environmental Considerations

Common to all plans is permitting for distribution line poles. Depending on the town, these poles will be set either by Verizon or by National Grid. Pole sets for Plan 1 would consist of routine requests and standard construction and no major obstacles are expected. Plan 2 and Plan 3 would require upgrading the 23kV supply system with 795 bare aluminum conductors and would have 12.47kV distribution under-build. This construction would occur along highly congested public roadways and could face opposition from the Town of Barrington and the City of Providence. Guying this type of construction may require private property easements which could be challenging to obtain and could increase the cost of the plans.

The Warren 115/12.47kV substation was initially permitted for six feeders. Therefore, the addition of two feeders at this station should be routine with no major issues anticipated. The station SPCC plan will need to be updated with the additional equipment. The new Warren feeders would be routed to Barrington. The feeders would utilize a bridge crossing and underground infrastructure to be built on a bike path as part of a Department of Transportation

(DOT) bridge rebuild project. The company is currently coordinating the bridge crossing with the DOT bridge rebuild project.

The option to build a new 115/12.47kV station at Phillipsdale has been reviewed at a conceptual level. Space at the station is limited, however, it is anticipated that sufficient space exists to build the proposed station. Construction of the new station will impact the existing 23/12.47kV station which needs to remain in-service during construction. It is anticipated that some of the existing equipment will need to be temporarily relocated while the new station is built. The existing station SPCC plan will need to be revised due to the new station.

The proposed 115/12.47kV station on First Street in East Providence will be built on a gas company owned site. The station will be supplied by a short tap from the 115kV line running thru the property. The 115kV tap will require a notification to the Rhode Island Energy Facility Siting Board (EFSB). The company is in the process of placing an Environmental Land Use Restriction (ELUR) on this site but it will not restrict the property from being used as a substation. The City of Providence has requested the company investigate undergrounding the 115kV line, E183W, to Franklin Square substation. One option is to install the E183W line riser structure at this site. The site appears to be large enough to accommodate both undergrounding the 115kV line and the proposed substation. Both projects will need to be coordinated.

The former Rumford substation site used to house a 23/4.16kV substation and has two 23kV supply lines running behind the site. This site is presently undeveloped. There are no major obstacles anticipated at this time that would prohibit the use of this site to install the proposed 23/12.47kV modular feeders and new taps from the 23kV supply lines.

Kent Corners substation is located in a small parcel of land as is located within a congested residential area. The proposed installation of two modular feeders at this station could face local opposition. In addition, the existing 4.16kV station would have to remain in service while the new 23/12.47kV modular feeders are being constructed which could impact the ability for the company to screen the station from the neighborhood. There have been numerous complaints about transformer noise at the station. Any construction at this location could result in potential neighborhood opposition.

6.4 Planned Outage Considerations

All three plans require work on 115kV supplied stations. Plan 1 and Plan 3 require tapping 115 kV transmission lines. Any required 115kV line outages will have to be coordinated with ISO-NE.

The existing Phillipsdale 23/12.47kV substation will have to remain in-service while the new 115/12.47kV substation at Phillipsdale is energized. This will require relocating some of the 12.47kV circuits. A preliminary review has not identified any major concerns with these relocations.

6.5 Asset Physical Security Considerations

National Grid Security department will be consulted during the design process for the new substations. Recommendations for improved security at existing area substations will also be solicited and incorporated.

6.6 System Loss Analysis

A loss analysis was conducted to compare Plan 1 to the existing system. The purpose of this comparison was to check that the recommended plan reduced losses, and by such a result would create a more efficient system. Table 6.6 demonstrates over 1MW of peak load loss savings with Plan 1.

TABLE 6.6 – Megawatt Loss Savings Analysis

Voltage Level	Existing Configuration	Plan 1 Configuration	MW Loss Savings
115kV	2.42	2.43	-0.01
23kV	0.99	0.27	0.72
12.47kV	4.96	4.79	0.17
4.16kV	0.28	0	0.28
Total	8.65	7.49	1.16

7. Conclusions and Recommendations

The three plans provide a comprehensive solution for the area and address all asset condition, safety, and reliability concerns. The plans address thermal loading concerns, provide capacity to supply new load growth, and addresses distribution planning criteria violations thru the study horizon period of 2030.

Plan 1 is recommended for implementation. Plan 1 provides a comprehensive solution to address all the concerns in the study area at least cost. The total cost of plan 1 is \$37.70M which is \$13.00M lower in cost than Plan 2 and \$3.50M lower in cost than Plan 3.

Plan 1 is least sensitive to load growth and offers the most flexibility for future expansion. Plan eliminates most of 23kV supply system consisting of predominantly roadway construction with exposure to motor vehicle accidents and tree related outages. When needed, additional distribution capacity can be added with a minimal investment on the supply system and minimal permitting impact. The recommended capital spending by fiscal year for Plan 1 is shown in Table 7.0 below:

TABLE 7.0: Recommended Capital Spend by Fiscal Year:

Description	FP	TOTAL	FY18	FY19	FY20	FY21	FY22	FY23	FY24	FY25	FY26	FY27
East Providence Sub (T-Line)	C049819	\$0.40	0.00	0.02	0.08	0.12	0.12	0.06				
East Providence Sub (T-Sub)	C049820	\$0.30	0.00	0.02	0.06	0.09	0.09	0.04				
East Providence Sub (D-Sub)	C046726	\$6.00	0.06	0.30	1.20	1.80	1.80	0.84				
East Providence Sub (D-Line)	C046727	\$7.40	0.07	0.37	1.48	2.22	2.22	1.04				
Warren Sub Expansion (D-Sub)	C065166	\$3.50	0.04	0.18	0.70	1.05	1.05	0.49				
Warren Sub Expansion (D-Line)	C065187	\$3.70	0.04	0.19	0.74	1.11	1.11	0.52				
Mink Street 23kV Retirement (D-Sub)	C065806	\$0.00										
Barrington Sub Retirement (D-Sub)	C065293	\$0.00										
Kent Corners Retirement (D-Sub)	C065295	\$0.00										
Waterman Ave Retirement (D-Sub)	C065297	\$0.00										
Phillipsdale Sub (T-Line)		\$0.40				0.00	0.02	0.08	0.12	0.12	0.06	
Phillipsdale Sub (T-Sub)		\$0.30				0.00	0.02	0.06	0.09	0.09	0.04	
Phillipsdale Sub (D-Sub)		\$6.00				0.06	0.30	1.20	1.80	1.80	0.84	
Phillipsdale Sub (D-Line)		\$3.72				0.04	0.19	0.74	1.11	1.11	0.52	
Common Items		\$1.21							0.11	0.20	0.50	0.40
T-Spend		\$1.40	\$0.01	\$0.04	\$0.14	\$0.22	\$0.25	\$0.24	\$0.21	\$0.21	\$0.10	\$0.00
D-Spend		\$31.53	\$0.21	\$1.03	\$4.12	\$6.28	\$6.67	\$4.83	\$3.02	\$3.11	\$1.86	\$0.40

8. Factors Influencing Futures Studies

Unexpected significant load growth is one factor that could affect future studies. The recommended plan initially installs a single transformer and four feeders at Phillipsdale and East Providence substations. However, both substations will be permitted for two transformers and eight feeders. At least eight additional feeders (or approximately 80MW of distribution capacity) can be installed to accommodate unexpected future load growth.


The Phillipsdale 115/23kV substation has numerous asset condition concerns which are being deferred. Loading on the 23kV station will be reduced to approximately 3MW and the station will supply only two industrial customers. It is recommended that this area be reviewed in the next few years and consideration be given to fully retire Phillipsdale 23kV station in lieu of performing any major asset replacement work.

A transmission study is currently being performed for the Southeastern Massachusetts and Rhode Island area. One potential plan involves extending the 115kV line from Bristol substation to Aquidneck Island. This will provide an option to eliminate the 23kV supply to Bristol substation and allow for the retirement of the 23kV station at Warren. If this transmission investment is to occur, it is recommended that any asset replacement work at the Warren 23kV station be compared against supplying Bristol substation with a second 115kV line. Even today, for various n-1 contingencies, the 23kV line is not capable of supplying the full Bristol load.

9. Appendix

9.1 Area Maps

FIGURE 9.1.1 – STUDY AREA



9.2 One Line Diagrams





FIGURE 9.2.2 – 23kV SUPPLY SYSTEM ONE-LINE DIAGRAM






FIGURE 9.2.4 – BARRINGTON SUBSTATION ONE-LINE DIAGRAM




FIGURE 9.2.5 – KENT CORNERS SUBSTATION ONE-LINE DIAGRAM





FIGURE 9.2.6 – PHILLIPDALE SUBSTATION ONE-LINE DIAGRAM








FIGURE 9.2.8 - WATERMAN SUBSTATION ONE-LINE DIAGRAM



9.3 Loadflow Diagrams


This section contains the electrical one-line loadflow diagrams. The diagrams show transformer and subtransmission power flows throughout the study area. Included below are notes and guides to assist the review of these diagrams.


General Layout





LEGEND

- Green = 5kV Class Equipment**
- Blue-Gray = 15kV Class Equipment**
- Aqua = 25kV Class Equipment**
- Tan = 35kV Class Equipment**
- Salmon = 46kV Class Equipment**
- Green = 69kV Class Equipment**
- Brown = 115kV Class Equipment**









9.4 CYME Radial Distribution Analysis Diagrams

Figure 9.4.1 – CYME East Bay Existing Configuration – Circuit Arrangement




Figure 9.4.2 – CYME East Bay Existing Configuration – Loading Analysis




Figure 9.4.3 – CYME East Bay Existing Co figuration – Voltage Analysis




Figure 9. .4 – CYME East Bay Plan 1 Configuration – Circuit Arrangement




Figure 9.4.5 – CYME East Bay Plan 1 Configuration – Loading Analysis





Figure 9.4.6 – CYME East Bay Plan 1 Configuration – Voltage Analysis




9.5 Arc Flash Analysis

Substation	Feeder	Voltage (kV)	LG Fault Current (Amps)	Clearing Time (secs)	Incident Energy (cal/cm ²)
BARRINGTON 4	4F1	12.47	4,972	0.2269	1.16
BARRINGTON 4	4F2	12.47	5,011	0.1404	0.73
BRISTOL 51A	51F2	12.47	4,590	0.3278	1.51
BRISTOL 51A	51F1	12.47	6,275	0.2951	2.07
BRISTOL 51A	51F3	12.47	6,797	0.3947	3.09
KENTS CORNER 47	47J2	4.16	7,673	0.1553	1.44
KENTS CORNER 47	47J1	4.16	7,756	0.1562	1.47
KENTS CORNER 47	47J3	4.16	7,872	0.1555	1.49
KENTS CORNER 47	47J4	4.16	8,142	0.1509	1.51
PHILLIPSDALE 20	20F2	12.47	4,711	0.2222	1.06
PHILLIPSDALE 20	20F1	12.47	4,712	0.1656	0.79
WAMPANOAG 48	48F5	12.47	6,077	0.3043	2.05
WAMPANOAG 48	48F6	12.47	6,080	0.3042	2.05
WAMPANOAG 48	48F2	12.47	6,165	0.3001	2.06
WAMPANOAG 48	48F1	12.47	6,351	0.2918	2.09
WAMPANOAG 48	48F3	12.47	6,472	0.2210	1.62
WAMPANOAG 48	48F4	12.47	6,590	0.2825	2.12
WARREN 5	5F2	12.47	6,586	0.2215	1.66
WARREN 5	5F4	12.47	6,597	0.3949	2.97
WARREN 5	5F1	12.47	7,069	0.4716	3.90
WARREN 5	5F3	12.47	7,199	0.3176	2.69
WATERMAN AVENUE 78	78F4	12.47	4,348	0.1691	0.73
WATERMAN AVENUE 78	78F3	12.47	4,551	0.1466	0.67

9.6 Fault Duty Analysis

Substation	Description	Position	Operating kV	Rated IC (A)	3-Phase Fault (A)	1-Phase Fault (A)
Barrington 4	VSA-12	4F1 VCR	12.4	12,000	4,286	5,054
Barrington 4	VSA	4F2 VCR	12.4	12,000	4,286	5,054
Bristol 51	SDV	2T23 VCB	23	20,000	4,033	2,583
Bristol 51	PVDB1 15.5-20-2	51F1 VCB	12.4	20,000	6,714	6,897
Bristol 51	PVDB1 15.5-20-2	51F2 VCB	12.4	20,000	3,869	4,660
Bristol 51	PVDB1 15.5-16-1	51F3 VCB	12.4	20,000	6,714	6,897
Bristol 51	PVDB1 15.5-20-1	1-2 VCB	12.4	20,000	6,714	6,897
Bristol 51	PVDB1 15.5-20-2	3-4 VCB	12.4	20,000	6,714	6,897
Bristol 51	PVDB1 15.5-20-2	51C2 VCB	12.4	20,000	3,869	4,660
Kents Corner 47	OZ-15-100	47J4 OCB	4.16	10,000	6,900	8,150
Kents Corner 47	OZ-210	47J3 OCB	4.16	10,000	6,900	8,150
Kents Corner 47	OZ-110	47J1 OCB	4.16	10,000	6,900	8,150
Kents Corner 47	OZ-210	47J2 OCB	4.16	10,000	6,900	8,150
Phillipsdale 20	23KS500-12C	3 TRF 2 BUS	23	18,000	8,890	1,101
Phillipsdale 20	FKD-25.8-11000	2243 OCB	23	11,000	8,890	1,101
Phillipsdale 20	SDO 23 500	2242 OCB	23	11,000	7,411	754
Phillipsdale 20	SDO 23 500	4342 OCB	23	11,000	8,890	1,101
Phillipsdale 20	FKD-25.8-11000-3	3 TR 1 BUS	23	18,000	8,890	1,101
Wampanoag 48	PVDB1 15.5	48F1 VCB	12.4	20,000	6,712	6,774
Wampanoag 48	PVDB1 15.5-16-1	48F2 VCB	12.4	20,000	7,120	7,190
Wampanoag 48	PVDB1 15.5-16-1	48F3 VCB	12.4	20,000	6,712	6,774
Wampanoag 48	PVDB1 15.5-20-2	48F4 VCB	12.4	20,000	7,120	7,190
Wampanoag 48	PVDB1 15.5-20-2	48F5 VCB	12.4	20,000	6,712	6,774
Wampanoag 48	PVDB1 15.5-20-2	48F6 VCB	12.4	20,000	7,120	7,190
Wampanoag 48	PVDB1 15.5-20-2	1-2 VCB	12.4	20,000	7,120	7,190
Wampanoag 48	PVDB1 15.5-20-2	3-4 VCB	12.4	20,000	7,120	7,190
Wampanoag 48	PVDB1 15.5-20-2	5-6 VCB	12.4	20,000	7,120	7,190
Warren 5	FKA-38-22000-6Y	5 TR OCB	23	22,000	16,463	16,280
Warren 5	345G1500	6 TR OCB	23	22,000	16,463	16,280
Warren 5	345G1500	2295 OCB	23	22,000	16,463	16,280
Warren 5	34.5KS1500-12D	2291 OCB	23	22,000	16,463	16,280
Warren 5	PVDB1 15.5-20-2	5F1 VCB	12.4	20,000	7311	7424
Warren 5	PVDB1 15.5-20-2	5F2 VCB	12.4	20,000	6652	6764
Warren 5	PVDB1 15.5-20-2	5F3 VCB	12.4	20,000	7311	7424
Warren 5	PVDB1 15.5-20-2	5F4 VCB	12.4	20,000	6652	6764
Warren 5	PVDB1 15.5-20-2	1-2 VCB	12.4	20,000	7311	7424
Warren 5	PVDB1 15.5-20-2	3-4 VCB	12.4	20,000	7311	7424
Waterman Ave 78	VSA-12	78F4 VCR	12.4	12,000	3920	2914
Waterman Ave 78	VSA	78F3 VCR	12.4	12,000	3920	2914
Waterman Ave 78	VSA	3-4 VCR	12.4	12,000	3920	2914

9.7 Plan Development – Common Items



9.8 Plan Development – Plan 1

FIGURE 9.8.1 – PHILLIPSDALE SUBSTATION ONE LINE-DIAGRAM (PLAN 1)




FIGURE 9.8.2 – EAST PROVIDENCE SUBSTATION ONE LINE-DIAGRAM (PLAN 1)




FIGURE 9.8.3 – EAST PROVIDENCE SUBSTATION SITE PLAN (PLAN 1)






FIGURE 9.8.5 – PROPOSED MAINLINE DISTRIBUTION NORTH (PLAN 1)




FIGURE 9.8.6 – PROPOSED MAINLINE DISTRIBUTION SOUTH (PLAN 1)



9.9 Plan Development – Plan 2

FIGURE 9.9.1 – PHILLIPSDALE SUBSTATION ONE-LINE DIAGRAM (PLAN 2)




FIGURE 9.9.2 – RUMFORD SUBSTATION ONE-LINE DIAGRAM (PLAN 2)




FIGURE 9.9.3 – KENT CORNERS SUBSTATION ONE-LINE DIAGRAM (PLAN 2)





FIGURE 9.9.4 – MINK STREET SUBSTATION ONE-LINE DIAGRAM (PLAN 2)



9.10 Plan Development – Plan 3

FIGURE 9.10.1 – PHILLIPSDALE SUBSTATION ONE-LINE DIAGRAM (PLAN 3)




FIGURE 9.10.2 – KENT CORNERS SUBSTATION ONE-LINE DIAGRAM (PLAN 3)






FIGURE 9.10.4 – PROPOSED 23KV SUPPLY SYSTEM (PLAN 3)

East Bay Area 23kv
2242-43-67-91 Lines



9.11 Distributed Generation Within the Study Area

FIGURE 9.11.1 – Existing and Proposed Distributed Generation – East Bay Area

Feeder #	Organization Name	Existing Capacity (kW)	Proposed Capacity (kW)	Type
2267	FORBES STREET PROJECT LLC	3000	0	Solar
2267	FORBES STREET PROJECT LLC	0	3000	Solar
53-20F1	NATIONAL SECURITY CORP	45.6	0	Solar
53-20F2	DAVID CHOPY	4	0	Solar
53-48F1	MARVIC ENTERPRISES INC	0	7	Solar
53-48F3	JENNY K FLANAGAN	0	2.15	Solar
53-48F4	EAST BAY STORAGE	0	75	Solar
53-4F2	ROGER E DESLAURIERS	3.87	0	Solar
53-4F2	NOAH PHILIP	3.44	0	Solar
53-51F2	JOHN BRANDO	4	0	Solar
53-51F2	ELIZABETH RADUCHA	5	0	Solar
53-51F3	SAFE-WAY AUTO SALES INC	50	0	Wind
53-51F3	CLEMS ELECTRIC CO	28	0	Solar
53-5F1	GEOFFREY ALLEN	0	3.6	Solar
53-5F2	WESLEY J MILLER	3.66	0	Solar
53-5F2	TYSAS AND COMPANY INC	1.29	0	Solar
53-5F3	THOMAS FAIRCHILD	0	0.57	Solar
53-5F3	BEN LUK	0	6.45	Solar
TOTAL		3,149	3,095	